



**Atacama
Large
Millimeter
Array**

ALMA Back End Central Reference Generator Stability Test for ALMA Phasing Project

BEND-55.03.00.00-0026-A-TDR

Version: A

Status: Released

2013-04-18

Prepared by:	Organization:	Date:
B. Shillue	NRAO	2013-04-18
Documentation PA Signature:		
Gretchen Stahlman	NRAO	
Approved by:		
Ephraim Ford	NRAO	
Herve Kurlandczyk	ESO	



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 2 of 12

CHANGE RECORD

Version	Date	Affected section(s)	ICO #	Reason/Initiation/Remarks
A	2013-04-18	All	-	Initial Release



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 3 of 12

TABLE OF CONTENTS

1. Description 4
 1.1. Purpose 4
2. Related Documents and Drawings 4
 2.1. Reference Documents 4
 2.2. Abbreviations and Acronyms 4
3. Equipment Used in Test 5
 3.1. H-Maser 5
 3.2. Central Reference Generator 5
 3.3. Phase Noise Test Set 6
4. Test Configuration 6
5. Test Results 8
 5.1. Allan Deviation and Phase Noise of CRG 8
 5.2. Allan Deviation and Phase Noise of H-Maser 10 MHz 10
 5.3. Discussion 11
 5.4. Further measurement of Delay Sensitivities 11
6. Conclusion 12

Table of Figures

Figure 1: CRG Block Diagram [RD 02] 6
Figure 2 – 1st Test configuration: CRG stability test 7
Figure 3 - 2nd Test configuration: maser stability test 7
Figure 4 - Allan Deviation of the CRG 10 MHz output versus the Maser 10 MHz output 8
Figure 5 - Phase Noise measured at CRG 10 MHz output 9
Figure 6 - Allan Deviation measured between Maser 5 MHz and 10 MHz outputs 10
Figure 7 – Phase Noise measured at H-maser output 11

List of Tables

Table 1- H-Maser Allan Deviation specification 5



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 4 of 12

1. Description

1.1. Purpose

This test report documents the results of tests meant to determine the suitability of the ALMA Central Reference Generator output signals for use in the ALMA Phasing Project.

2. Related Documents and Drawings

2.1. Reference Documents

- [RD 1] T4-Science iMaser 3000 Installation, Operations, and Maintenance Manual, Doc# T4S-Man-0012
- [RD 2] BEND-55.03.00.00-002-A-DWG, ALMA Central Reference Generator Production Block Diagram
- [RD 3] Symmetricom 5115A Data sheet, “High Performance Phase Noise and Allan Deviation Test Set, DS 5115A Doc 102612
- [RD 4] Symmetricom 5120A/5120A-01/5115A Phase Noise Test Set, Operations and Maintenance Manual, DOC05120A, RevM

2.2. Abbreviations and Acronyms

ALMA	Atacama Large Millimeter Array
APP	ALMA Phasing Project
CLOA	Central LO Article
CRG	Central Reference Generator
CVR	Central Variable Reference
LO	Local Oscillator
PLL	Phase Locked Loop
VCXO	Voltage Controlled Crystal Oscillator
VLBI	Very Long Baseline Interferometry



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 5 of 12

3. Equipment Used in Test

3.1. H-Maser

The H-maser used by the ALMA Phasing Project is the T4-Science iMaser3000 [RD 01]. This maser was already in operation at Haystack Laboratory, which made Haystack the best location for the testing. The maser has outputs at 5 MHz (2), 10 MHz (4), and 100 MHz (2). The maser specification is

Time	Allan Dev
1 sec	8e-14
10 sec	1.9e-14
100 sec	4e-15
1000 sec	2e-15

Table 1- H-Maser Allan Deviation specification

3.2. Central Reference Generator

The Central Reference Generator is a custom ALMA Line Replaceable Unit(LRU) which provides the references for Central LO, Correlator, and Antennas. The block diagram is shown below. The 5 MHz Wenzel VCXO is phase-locked to an external reference (called “Maser” in the diagram) and this phase locked crystal oscillator is used to derive 5 MHz, 10 MHz, 125 MHz, and 2 GHz references as shown in Figure 1. The 10 MHz output in particular must be phase stable for VLBI because it provides the reference for the 1st Local Oscillator Central Variable Reference (CVR) microwave synthesizers.



ALMA Back End Central Reference Generator Stability Test for ALMA Phasing Project

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 6 of 12




Figure 1: CRG Block Diagram [RD 02].

3.3. Phase Noise Test Set

For the measurements detailed below, the instrument used to measure the output phase and Allan Variance was Symmetricom 5115A Phase Noise Test Set [RD 03], [RD 04].

4. Test Configuration

Two test configurations were used. In the first, the 5 MHz output of the maser was used to lock the CRG. The phase test set measured between the CRG 10 MHz output and the maser 10 MHz output. This configuration measured the CRG stability (against the maser), as shown in Figure 2.

National Radio Astronomy Observatory ALMA Project Back End IPT			
ALMA Central Reference Generator Production Block Diagram			
DRAWN BY BEND-55.03.00.00-0026-A-DWG	DATE 2009-06-18	DESIGNED BY Laura Newton & Phillip Lopez	
DRAWN BY L. Newton & P. Lopez	APPROVED BY IPT LEAD	APPROVED BY	
DRAWING NO. A	DRAWING REV A	SCALE 1:1	SHEET 2 OF 2



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 7 of 12




Figure 2 – 1st Test configuration: CRG stability test

In the second test configuration, the 5 MHz output of the maser was measured against the 10 MHz output. This configuration measured the stability of the maser 10 MHz output, as shown in Figure 3.




Figure 3 - 2nd Test configuration: maser stability test



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 8 of 12

5. Test Results

5.1. Allan Deviation and Phase Noise of CRG

06 Mar 2013 11:58:06
14h 23m

Symmetricom5115A




Figure 4 - Allan Deviation of the CRG 10 MHz output versus the Maser 10 MHz output



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 9 of 12

06 Mar 2013 11:58:11
14h 23m

$\mathcal{L}(f)$ Phase Noise at 10.0 MHz (dBc/Hz)

Symmetricom5115A




Figure 5 - Phase Noise measured at CRG 10 MHz output



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 10 of 12

5.2. Allan Deviation and Phase Noise of H-Maser 10 MHz

05 Mar 2013 16:30:57
1h 3m

Symmetricom5115A




Figure 6 - Allan Deviation measured between Maser 5 MHz and 10 MHz outputs



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 11 of 12

05 Mar 2013 16:31:04
1h 3m

$\mathcal{L}(f)$ Phase Noise at 5.0 MHz (dBc/Hz)

Symmetricom5115A




Figure 7 – Phase Noise measured at H-maser output

5.3. Discussion

A comparison of Figure 6 vs. Figure 4, and Figure 7 vs. Figure 5, clearly shows that the CRG introduces unwanted delay and noise. In particular, the Allan deviation plots show and approximate order of magnitude increase in the phase deviation above 100 seconds integration time. This will have a negative impact for the ALMA Phasing Project VLBI.

5.4. Further measurement of Delay Sensitivities

Further testing was done on the CRG to attempt to pinpoint the cause of the delay sensitivity. The module was opened up, and the temperature of the internal components was perturbed by either physically warming them by hand, or by changing the local air flow. There are three components in the 10 MHz path: the crystal oscillator, Amplifonix 15 dB amplifier, and Wenzel doubler. An initial test of heating by pressing on the components with fingers for 60 seconds appeared to indicate that the amplifier was the most sensitive device, followed by the doubler, and the VCXO was not very sensitive.



**ALMA Back End
Central Reference Generator
Stability Test for ALMA Phasing
Project**

Doc # : BEND-55.03.00.00-0026-A-TDR
Date: 2013-04-18
Status: Released
Page: 12 of 12

The next day (overnight March 5-6), the fan speed was reduced and the CRG warmed from 25.9 to 27 deg C, and the phase change was 140 psec, for a temperature coefficient of 127 psec/deg C. It was later confirmed that the amplifier was the dominant contributor as its temperature coefficient was measured independently to be -110 psec/deg C (+/- 20%), and the doubler was ~ 20 psec/deg C.

6. Conclusion

The CRG 10 MHz output is not stable enough for the APP VLBI science. A remedy should be considered, possibly either:

- Replacing the unstable components in the CRG, or
- Using the 10 MHz output of the maser to directly input to the ALMA CVR.